



# Certificate of Compliance

CERTIFICATE

**Applicant:** Victron Energy B.V.  
De Paal 35  
1351 JG Almere  
The Netherlands

**Product:** Storage System

**Model:** MultiPlus-II 48/3000/35-32  
MultiPlus-II 48/3000/35-32 GX  
MultiPlus-II 48/5000/70-50  
MultiPlus-II 48/5000/70-50 GX  
MultiPlus-II 24/3000/70-32  
MultiPlus-II 24/3000/70-32 GX

**Intended use:**

Automatic disconnection device with single-phase mains surveillance in accordance with IEC 62116 for photovoltaic systems with single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

**Applied standards and guidelines:**

SOP-9-1\_14 GCC Certification Program, 11/20

Based on:

**IEC 62116:2014**

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

**Report No:** 17PP264-25

**Certificate No:** 20-128-02

**Date of issue:** 2021-02-17

**Kiwa Primara GmbH**  
Gewerbestraße 28  
87600 Kaufbeuren  
Germany  
Tel. +49 8341 99726-0  
info@primara.net  
www.kiwa.de



*Tanja Rottach*

- Digitally signed | see <http://ca.kiwa-deutschland.de> for more details -

**Tanja Rottach**  
Certification Engineer