

# Certificate of Conformity


Certificate Number: CN-PV-210178R1

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Shenzhen Growatt New Energy Co., Ltd 4-13/F,Building A,Sino-German(Europe) Industrial Park, Hangcheng Ave,Bao'an District,Shenzhen,China
<b>Product:</b>	PV Grid inverter
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	MAX 80KTL3-X LV, MAX 100KTL3-X LV, MAX 110KTL3-X LV, MAX 120KTL3-X LV, MAX 125KTL3-X LV, MAX 133KTL3-X LV, MAX 125KTL3-X MV, MAX 136KTL3-X MV, MAX 150KTL3-X MV, MAX 80KTL3-X2 LV, MAX 100KTL3-X2 LV, MAX 110KTL3-X2 LV, MAX 120KTL3-X2 LV, MAX 125KTL3-X2 LV, MAX 133KTL3-X2 LV, MAX 125KTL3-X2 MV, MAX 136KTL3-X2 MV, MAX 150KTL3-X2 MV
<b>Brand Name&lt;s&gt;:</b>	GROWATT
<b>Product Complies with:</b>	EN IEC 61000-6-4:2019 (IEC 61000-6-4:2018) EN IEC 61000-6-2:2019 (IEC 61000-6-2:2016) EN 61000-3-12 :2011(IEC 61000-3-12:2011+A1:2021) EN IEC 61000-3-11:2019 (IEC 61000-3-11:2017)
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China
<b>Test Report No.&lt;s&gt;:</b>	210223039GZU-001 Amendment 1

Replaces certificate CN-PV-210178 dated 23 July 2021

Additional information in Appendix.



Signature

Certification Manager: Grade Ye

Date: 15 September 2022

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-210178R1

Model	MAX 80KTL3-X LV	MAX 100KTL3-X LV	MAX 110KTL3-X LV	MAX 120KTL3-X LV	MAX 125KTL3-X LV
Max.PV voltage	1100Vdc				
PV voltage range	180V – 1000Vdc				
Max.input current	32A*7	32A*10			
PV Isc	40A*7	40A*10			
Number of strings per MPPT	2				
Nominal output voltage	3W/N/PE, 230/400Vac				
Nominal output Frequency	50/60Hz				
Max.output current	133.7A	167.1A	183.8A	200.5A	208.9A
Max.output power	80KW	100KW	110KW	120KW	125KW
Max.apparent power	88KVA	110KVA	121KVA	132KVA	137.5KVA
Power factor range	0.8Leading – 0.8 lagging				
Safety level	Class I				
Ingress Protection	IP 66				
Operation Ambient Temperature	-30°C - +60°C				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Model	MAX 133KTL3-X LV	MAX 125KTL3-X MV	MAX 136KTL3-X MV	MAX 150KTL3-X MV
Max.PV voltage	1100Vdc			
PV voltage range	180V – 1000Vdc			
Max.input current	32A*10			
PV Isc	40A*10			
Number of strings per MPPT	2			
Nominal output voltage	3W/N/PE, 230/400Vac	3W/PE, 277/480Vac		
Nominal output Frequency	50/60Hz			
Max.output current	222.3A	165.4A	179.9A	198.5A
Max.output power	133KW	125KW	136KW	150KW
Max.apparent power	146.3KVA	137.5KVA	149.6KVA	165.0KVA
Power factor range	0.8Leading – 0.8 lagging			
Safety level	Class I			
Ingress Protection	IP 66			
Operation Ambient Temperature	-30°C - +60°C			
Software version	TN1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Model	MAX 80KTL3-X2 LV	MAX 100KTL3-X2 LV	MAX 110KTL3-X2 LV	MAX 120KTL3-X2 LV	MAX 125KTL3-X2 LV
Max.PV voltage	1100Vdc				
PV voltage range	180V – 1000Vdc				
Max.input current	45A*8	45A*8			
PV Isc	56.5A*8	56.5A*8			
Number of strings per MPPT	2				
Nominal output voltage	3W/N/PE, 230/400Vac				
Nominal output Frequency	50/60Hz				
Max.output current	133.7A	167.1A	183.8A	200.5A	208.9A
Max.output power	80KW	100KW	110KW	120KW	125KW
Max.apparent power	88KVA	110KVA	121KVA	132KVA	137.5KVA
Power factor range	0.8Leading – 0.8 lagging				
Safety level	Class I				
Ingress Protection	IP 66				
Operation Ambient Temperature	-30°C - +60°C				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Model	MAX 133KTL3-X2 LV	MAX 125KTL3-X2 MV	MAX 136KTL3-X2 MV	MAX 150KTL3-X2 MV
Max.PV voltage	1100Vdc			
PV voltage range	180V – 1000Vdc			
Max.input current	45A*8			
PV Isc	56.5A*8			
Number of strings per MPPT	2			
Nominal output voltage	3W/N/PE, 230/400Vac	3W/PE, 277/480Vac		
Nominal output Frequency	50/60Hz			
Max.output current	222.3A	165.4A	179.9A	198.5A
Max.output power	133KW	125KW	136KW	150KW
Max.apparent power	146.3KVA	137.5KVA	149.6KVA	165.0KVA
Power factor range	0.8Leading – 0.8 lagging			
Safety level	Class I			
Ingress Protection	IP 66			
Operation Ambient Temperature	-30°C - +60°C			
Software version	TN1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.