

# Certificate of Conformity


Certificate Number: CN-PVES-240437

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Shenzhen Growatt New Energy Co., Ltd 4-13/F, Building A, Sino-German (Europe) Industrial Park, Hangcheng Ave, Bao'an District, Shenzhen, China.
<b>Manufacturer:</b>	Shenzhen Growatt New Energy Co., Ltd 4-13/F, Building A, Sino-German (Europe) Industrial Park, Hangcheng Ave, Bao'an District, Shenzhen, China.
<b>Product:</b>	PV Micro Inverter
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	NEO 600M-X, NEO 800M-X, NEO 1000M-X
<b>Brand Name&lt;s&gt;:</b>	GROWATT
<b>Product Complies with:</b>	Commission Regulation (EU) 2016/631 of 14 April 2016 (NC RfG) establishing a network code on the requirements for connecting generating units to the network (Journal of Laws UE L 112/1 of 27 April 2016); PSE:18 December 2018: General Application Requirements resulting from the Regulation of the EU Commission 2016/631 of April 14, 2016 establishing the network code on the requirements for connecting generating units to the grid - approved by the Decision of the President of the Energy Regulatory Office DRE.WOSE.7128.550.2.2018.ZJ of January 2, 2019; PTPIREE, 2024: Conditions and procedures for the use of certificates in the process of connecting power generation modules to power grids. Type approval for Type A PPMs Type 1a product certification scheme according to ISO/IEC 17067:2013 Certification procedure SMS-PV-OP-19
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2 <sup>nd</sup> Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
<b>Test Report No.&lt;s&gt;:</b>	240813106GZU-001, 11 September 2024

Additional information in Appendix.

Signature



Certification Manager: Grady Ye

Issue Date: 19 September 2024

Valid Until: 18 September 2029



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-240437

<b>Product Complies with:</b>	EN 50549-1:2019 Requirements for generating plants to be connected in parallel with distribution networks Part 1: Connection to a LV distribution network - Generating plants up to and including Type B
-------------------------------	---

The following functionalities have been assessed based on the rules for the use of certificate for Power Park Modules (PPMs), as specified in chapter 7 and 9 of the PTPIREE 2024. The functions denoted "Not Applicable" in the table of chapter 7 has not been included.

Capability	NC RfG	PSE 2018-12	Type A	Assessment result
Frequency range	13.1(a)	13.1(a)(i)	x	Compliant
Rate of Change of Frequency (ROCOF) Withstand capability, df/dt	13.1(b)	13.1(b)	x	Compliant
Remote cessation of active power	13.6	13.6	x	Compliant
Limited Frequency Sensitive Mode – Over frequency (LFSM-O)	13.2	13.2(a).(b).(f)	x	Compliant

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-240437

### Ratings & Principle Characteristics:

Model	NEO 600M-X	NEO 800M-X	NEO 1000M-X
Max.PV voltage	60Vdc		
MPPT voltage	28-60Vdc		
Max.input current	2*18A		
PV Isc	2*23A		
Nominal output voltage	230Vac		
Nominal output Frequency	50/60Hz		
Rated output current	2.61A	3.48A	4.35A
Max. output power	600W	800W	1000W
Max. apparent power	600VA	800VA	1000VA
Power factor range	0.8Leading~0.8Lagging		
Safety level	Class I		
Ingress Protection	IP 67		
Operation Ambient Temperature	-40°C - +65°C		
Software version	GJ1.0		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.