



TM

Ref. Certif. No.

DE 2-042865

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Grid-connected PV Inverter

Name and address of the applicant

GoodWe Technologies Co., Ltd.  
No.90 Zijin Rd., New District  
215011 Suzhou, P.R. China

Name and address of the manufacturer

GoodWe Technologies Co., Ltd.  
No.90 Zijin Rd., New District  
215011 Suzhou, P.R. China

Name and address of the factory

See additional page(s)

Ratings and principal characteristics

Vmax PV [Vd.c.] : 1100, 850  
MPPT Voltage Range [Vd.c.] : 140-1000, 140-700

Trademark (if any)

GOODWE

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

GW23KLV-SDT-BR30 , GW33K-SDT-C30 , GW36K-SDT-C30 ,  
GW37K5-SDT-BR30 , GW40K-SDT-C30Additional information (if necessary may  
also be reported on page 2)

Detail information refer to test report CN24D3VL 001.

A sample of the product was tested and  
found to be in conformity withIEC 62109-2:2011  
IEC 62109-1:2010As shown in the Test Report Ref. No. which  
forms part of this Certificate

CN24D3VL 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland LGA Products GmbH  
Tillystr. 2, 90431 Nürnberg, Germany  
Phone + 49 221 806-1371  
Fax + 49 221 806-3935  
Mail: cert-validity@de.tuv.com  
Web : www.tuv.com

Date: 2024-09-25

Signature:

A. Chen

1. GoodWe Technologies Co., Ltd.  
No.90 Zijin Rd., New District  
215011 Suzhou  
P.R. China
  
2. GoodWe (GuangDe) Power Supply  
Technology Co., Ltd.  
No. 208, Tong Rui East Road  
Guangde  
Anhui, P.R. China

**Additional information (if necessary)**

Report Ref. No. : CN24D3VL 001

Date: 2024-09-25

Signature:



A. Chen