

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD  
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

# CERTIFICATE

No. Z2 093848 0003 Rev. 00

**Holder of Certificate:** Worldwide Energy and  
Manufacturing (Nantong) Co., Ltd.  
No. 88 Qifeng Road  
226500 Rugao City, Nantong, Jiangsu  
PEOPLE'S REPUBLIC OF CHINA

## Certification Mark:



## Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
Poly-crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 704061824102-00

**Valid until:** 2024-01-01

**Date,** 2019-01-04 ( Zhulin Zhang )



Product Service

# CERTIFICATE

No. Z2 093848 0003 Rev. 00

## Model(s):

AS-6P-xxxW (xxx=315-345 in step of 5W)  
 AS-6P30-xxxW (xxx=265-290 in step of 5W)  
 AS-6P27-xxxW (xxx=235-260 in step of 5W)  
 AS-6P24-xxxW (xxx=210-230 in step of 5W)  
 AS-6P21-xxxW (xxx=185-200 in step of 5W)  
 AS-6P18-xxxW (xxx=160-175 in step of 5W)  
 xxx is standing for rated output power at STC

## Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790

## Tested according to:

IEC 61215-1(ed.1)  
 IEC 61215-1-1(ed.1)  
 IEC 61215-2(ed.1)  
 IEC 61730-1(ed.2)  
 IEC 61730-2(ed.2)

## Production Facility(ies):

093848

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD  
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT